

Test Results



International Standards Test Results Summary

FOAM CONCENTRATE	UL 162	ICAO Level B	LAST FIRE	EN 1568 Part 1	EN 1568 Part 2	EN 1568 Part 3	EN 1568 Part 4	IMO MSC.1/ Circ. 1312
1% AFFF-LF	✓	✓				✓		✓
3% AFFF-LF		✓				✓		✓
6% AFFF-LF		✓				✓		
3% AFFF		✓				✓		
1x1% AR-AFFF						✓	✓	✓
1x3% AR-AFFF						✓	✓	
3x3% AR-AFFF				✓	✓	✓	✓	✓
1% F3				✓	✓	✓		
3% F3						✓		
3x3% AR-F3						✓	✓	

EN 1568 Parts 3 & 4 Classification

Foam	Standard	Fuel	Fresh Water	Seawater	Fuel	Fresh Water	Seawater
1% AFFF-LF	EN 1568: 2018 Part 3	Heptane	I+A	I+A			
3% AFFF-LF	EN 1568: 2018 Part 3	Heptane	I+A	I+A			
6% AFFF-LF	EN 1568: 2008 Part 3	Heptane	IC	IB			
3% AFFF	EN 1568: 2008 Part 3	Heptane	IA	IA			
1x1% AR-AFFF	EN 1568: 2008 Part 3	Heptane	IB	IB			
	EN 1568: 2008 Part 4	Acetone	IC	IC	Isopropanol	IB	IB
1x3% AR-AFFF	EN 1568: 2008 Part 3	Heptane	IB	IB			
	EN 1568: 2008 Part 4	Acetone	IB	IC	Isopropanol	IB	IB
3x3% AR-AFFF	EN 1568: 2008 Part 3	Heptane	IA				
	EN 1568: 2008 Part 4	Acetone	IA		Isopropanol	IA	
1% F3	EN 1568: 2018 Part 3	Heptane	IB	IIIC	Diesel	I+A	I+A
3% F3	EN 1568: 2018 Part 3	Heptane	IB				
3x3% AR-F3	EN 1568: 2018 Part 3	Heptane	IB	IB			
	EN 1568: 2018 Part 4	Acetone	IB				

Rev230725